

CONSTRUCTION

- ALL UNDERGROUND AS PER "AS BUILT"
- NEW EXISTING RETIRE FUTURE
 - ALL EXISTING U/G ASSETS COLOR 66
 - NEW O/H CONDUCTOR
 - EXISTING O/H CONDUCTOR
 - EXISTING O/H CONDUCTOR TO BE RETIRED
 - EXISTING STAY TO BE RETIRED
 - EXISTING POLE TO BE RETIRED
 - POLE TYPE: CONCRETE, WOOD
 - POLE FOOTINGS: CONCRETE, LOG
 - TELECOM CABLE
 - GAS PIPE
 - WATER PIPE

AS BUILT

- HY 22KV U/G CABLE 18.5/31.22.2A, 3X/CH 18.51
- LV MAINS U/G CABLE 18.5/4/LV, SA/X 18.30
- LV SERVICE U/G CABLE 18.5/4/LV, CX 18.20
- PUBLIC LIGHTING CABLE 4mm 18.20
- SUPERVISORY CABLE 18.20
- HY MAINS STRAIGHT JOINT
- LV MAINS STRAIGHT JOINT
- LV SERVICE TEE JOINT
- LV MAIN TEE JOINT
- INSULATED END
- SEALED END
- U/G CABLE CUT END
- ELECTRICAL DUCT 8 SIZE
- ELECTRICAL DUCT 18mm OUTSIDE DIA UNLESS SHOWN
- PIPE (OTHER AUTHORITIES)
- METER BOX
- SERVICE PIT
- VC ROADS PIT
- PARALLELLING PILLAR
- CABLE HEAD POLE- HV/LV
- SUBTRANSMISSION POLE
- SUBTRANSMISSION POLE HV
- SUBTRANSMISSION POLE HV/LV
- HV/LV POLE
- SINGLE POLE SUBSTATION
- HV POLE
- LV POLE
- NEW
- EXISTING
- 22/10.2KV SWITCH/FUSE POLE
- GROUND STAY
- GROUND STAY SIZE
- AERIAL STAY
- AERIAL STAY SIZE
- POLE NUMBER
- POLE LENGTH/(HEIGHT)/STRENGTH/TIME TYPE
- COMMUNICATIONS PIT
- 80W HPS, MOUNTED AT 5.5m
- 100W HPS, MOUNTED AT 5.5m
- 150W HPS, MOUNTED AT 10m
- 250W HPS, MOUNTED AT 12.5m
- 400W HPS, MOUNTED AT 15m
- PUBLIC LIGHT (AS SPECIFIED)
- 2x2W T5 FLUORO
- 2x2W T5 FLUORO
- 3W COMPACT FLUORO
- 12W COMPACT FLUORO
- PUBLIC LIGHT POLE
- FABRICATED LIGHTING POLE
- TRACTION POLE
- IMPACT RESISTANT POLE (FRANGIBLE)
- FRANGIBLE SLIP POLE
- DEPTH OF EARTH COVER TO TOP OF CABLE
- DEPTH TO TOP OF OTHER SERVICES/OBSTRACTIONS
- BOUNDARY OR BUILDING LINE
- KERB LINE
- HOUSE No
- LOT No
- LV LOW VOLTAGE CABLE
- TB TITLE BOUNDARY
- KB BACK OF KERB
- IP INTERSECTION POINT
- D/E DUCT END
- O/C OUT OF COMMISSION
- CABLE HEAD POLE
- ASBESTOS CEMENT
- EW EARTHWARE
- GI GALVANIZED IRON
- PVC POLYVINYL CHLORIDE
- RC REINFORCED CONCRETE
- P/L PUBLIC LIGHTING
- FH FIRE HYDRANT
- SWD STORMWATER DRAIN
- PROJECTION
- CENTRELINE
- P & W POST AND WIRE MESH FENCE
- C/W CHAIN WIRE MESH
- SJ STRAIGHT JOINT HV/LV
- TJ TEE JOINT (H-MAIN, S-SERVICE)
- TP TURNING OR TANGENT POINT
- HV HIGH VOLTAGE CABLE

NOTE

This plan is a representation of a cable (asset) that is not owned or maintained by United Energy Distribution Pty Limited (UEDPL). UEDPL and its employees, contractors and agents make no representations as to the accuracy of this plan. All inquiries about this asset should be directed to the asset owner listed below. You will need to obtain its full terms and conditions to carry out excavations within the vicinity of this asset.

The asset owner must also comply with relevant regulatory requirements including the Electricity Safety Act 1998 (the Act) relating to relocating existing assets and installing new or additional assets. If, under the Act, the asset owner is required to re-submit modifications to this plan to UEDPL, it should ensure that any such modifications meet UEDPL's minimum plan standards.

"For use on the United Energy Distribution Network Only"

NOTE: CONDUIT & CABLE SIZES MUST BE SHOWN

CONDUIT SIZE	XXX
CABLE SIZE	XXX



REVISION	DATE	REV	DESCRIPTION	CHKD	APPR
		/			
		/			
		/			
		/			

REFERENCES	ASSET OWNER, CONTACT No:	XX
	ASSET OWNER REF & DISTRIBUTION NIM No:	XX
	DATE INSTALLED:	XX
	MAP: MELWAY	MAP PAGE: XX XX

ASSET OWNER	INSERT LOGO HERE
ELECTRICAL DISTRIBUTION NETWORK OWNER	

DRAWN	XX	XX
DESIGN CHECKED	XX	XX
ASSET OWNER APPR	XX	XX
DATE ACCEPTED	XX	XX

DRG No:	UE5-PRV-XXXXX	X
AS BUILT UG CABLE DETAILS SMART BUS SIGN		
TEMPLATE NAME	UE99-PRV-AT Rev. C	
MODEL SPACE	LANDSCAPE	DRAWING STATUS
		CURRENT